

# EKO Line Boiler

Manufactured by:  
Eko-Vimar Orlanski

Distributed by:  
New Horizon Corporation, Inc.  
www.newhorizoncorp.com

FUEL TYPE:	WOOD
MAX DRAFT AT FLUE COLLAR:	0.085 Inches of Water
ELECTRICAL RATING:	115 Volts, 4 Amps, 60 Hz
FLOORING REQUIREMENTS:	CONCRETE (noncombustible)
MINIMUM CLEARANCE TO COMBUSTIBLE SURFACES:	Left and Right: 18" Top, Rear, and Front: 36"

**DO NOT CONNECT THIS UNIT  
TO A CHIMNEY FLUE SERVING  
ANOTHER APPLIANCE**

Tested &  
Listed By



Portland  
Oregon USA

OMNI-Test Laboratories, Inc.

409-O-01-2

Tested UL 391 and CSA-B366.1